


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	6.479	7,5	629	280	7,6	79	10	87	96
2	5.812	7,4	645	305	7,8	64	5	90	98
3	4.973	7,8	794	419	8,0	63	13	92	97
4	4.976	7,6	745	328	7,7	67	15	91	95
5	5.861								
6	6.806								
7	6.528	7,5	877	400	7,3	62	8	93	98
8	6.525	7,5	811	420	7,6	69	10	92	98
9	6.545	7,5	852	400	7,6	60	13	93	97
10	6.283	7,6	794	331	7,5	75	15	91	95
11	5.963								
12	6.198								
13	7.037								
14	6.858	7,4	844	480	7,3	70	13	92	97
15	6.431	7,5	794	340	7,4	63	7	92	98
16	6.509	7,4	662	300	7,7	57	13	91	96
17	6.379	7,6	943	457	7,2	68	15	93	97
18	6.542	7,6	927	613	7,6	78	13	92	98
19	7.149								
20	7.850								
21	7.799	7,2	877	440	7,4	63	12	93	97
22	7.573	7,3	712	340	7,4	57	12	92	96
23	7.218	7,4	910	400	7,4	82	14	91	96
24	8.092	7,2	1.001	414	7,4	69	13	93	97
25	8.744	7,3	869	444	7,4	74	13	91	97
26	8.861								
27	9.238								
28	8.893	7,4	902	440	7,2	66	14	93	97
29	6.739	7,3	794	380	7,4	78	14	90	96
30	7.191	7,4	852	369	7,6	81	11	90	97
MED	6.935	7,4	821	395	7,5	69	12	92	97
MIN	4.973	7,2	629	280	7,2	57	5	87	95
MAX	9.238	7,8	1.001	613	8,0	82	15	93	98
TOTAL	208.052	-	-	-	-	-	-	-	-

	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	10.751	7,2	861	420	8,7	56	10	93	98
2	11.501	7,2	1.506	500	8,2	83	11	94	98
3	11.093	7,3	894	436	8,8	76	16	91	96
4	11.271	7,3	968	464	8,8	63	14	93	97
5	11.456								
6	11.273								
7	10.305	7,3	894	460	8,7	78	15	91	97
8	10.408	7,4	943	500	7,5	74	12	92	98
9	10.539	7,3	960	450	7,6	73	9	92	98
10	10.932	7,4	844	413	7,6	60	14	93	97
11	9.467								
12	8.717								
13	9.471								
14	9.604	7,1	910	600	7,3	88	11	90	98
15	10.691	7,3	819	460	7,7	61	14	93	97
16	9.868	7,3	728	306	8,0	84	19	88	94
17	10.905	7,4	761	361	8,1	98	19	87	95
18	10.449	7,3	993	602	7,5	74	13	93	98
19	10.567								
20	10.867								
21	9.453	7,3	1.001	480	7,8	84	13	92	97
22	11.160	7,1	811	380	8,3	35	8	96	98
23	10.649	7,3	952	400	8,1	84	13	91	97
24	10.257	7,1	869	431	7,9	86	13	90	97
25	10.459	7,1	1.034	583	7,7	91	19	91	97
26	10.296								
27	9.753								
28	8.775	7,4	927	460	7,6	81	12	91	97
29	9.698	6,8	1.456	440	8,2	74	11	95	98
30	9.763	7,3	960	479	8,0	81	11	92	98
MED	10.347	7,2	957	458	8,0	75	13	92	97
MIN	8.717	6,8	728	306	7,3	35	8	87	94
MAX	11.501	7,4	1.506	602	8,8	98	19	96	98
TOTAL	310.400	-	-	-	-	-	-	-	-

# Rendimientos EDAR La Barrosa - Junio'09



## Rendimientos EDAR El Torno - Junio'09

