


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	8.105	7,3	720	350	7,6	60	16	92	95
2	7.674	7,3	844	463	7,2	72	15	92	97
3	7.803								
4	9.212								
5	9.422	7,2	861	360	7,2	75	14	91	96
6	9.180	7,3	894	420	7,4	66	14	93	97
7	9.749	7,4	712	389	7,3	72	13	90	97
8	9.663	7,5	877	481	7,4	73	12	92	97
9	9.439	7,4	736	344	7,4	68	14	91	96
10	9.875								
11	10.399								
12	9.484	7,4	894	440	7,5	76	19	92	96
13	9.450	7,5	952	460	7,2	72	15	92	97
14	9.315	7,5	927	470	7,3	103	11	89	98
15	9.660	7,5	629	282	7,6	86	18	86	93
16	9.152	7,5	811	406	7,3	72	14	91	97
17	10.172								
18	10.696								
19	9.862	7,5	803	380	7,3	46	14	94	96
20	10.208	7,6	877	340	7,9	76	16	91	95
21	10.447	7,5	695	335	7,4	77	14	89	96
22	10.802	7,5	836	413	7,4	82	11	90	97
23	10.948	7,5	827	475	7,5	72	14	91	97
24	11.317								
25	11.707								
26	10.093	7,4	918	440	7,5	70	10	92	98
27	10.857	7,5	811	500	7,5	65	8	92	98
28	11.113	7,4	745	367	7,4	62	11	92	97
29	10.903	7,4	761	389	7,4	90	15	88	96
30	10.908	7,4	844	431	7,6	80	14	91	97
31	11.250								
MED	9.963	7,4	817	406	7,4	73	14	91	97
MIN	7.674	7,2	629	282	7,2	46	8	86	93
MAX	11.707	7,6	952	500	7,9	103	19	94	98
TOTAL	308.865	-	-	-	-	-	-	-	-

	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	9.413	7,3	712	372	7,8	58	7	92	98
2	9.553	7,2	985	486	8,0	79	18	92	96
3	9.542								
4	10.568								
5	8.544	7,1	976	500	7,5	84	16	91	97
6	8.940	7,3	960	380	7,5	78	18	92	95
7	9.489	7,3	894	464	7,6	94	10	89	98
8	9.455	7,0	943	471	7,6	78	15	92	97
9	8.807	7,2	728	389	7,6	69	10	90	97
10	9.585								
11	8.377								
12	8.814	7,1	695	360	7,5	71	8	90	98
13	8.541	7,5	861	400	7,8	94	12	89	97
14	8.438	7,3	910	463	7,8	104	10	89	98
15	8.988	7,0	927	471	7,6	78	13	92	97
16	8.574	7,1	778	356	7,6	79	13	90	96
17	9.214								
18	8.915								
19	7.923	7,3	894	340	7,4	78	13	91	96
20	8.750	7,3	794	320	7,7	60	7	93	98
21	8.609	7,2	927	471	7,3	66	7	93	99
22	9.549	7,2	885	456	7,2	99	17	89	96
23	8.130	7,2	885	500	7,6	78	15	91	97
24	9.517								
25	8.781								
26	7.815	7,3	827	340	7,6	76	20	91	94
27	8.486	7,6	778	340	7,9	84	10	89	97
28	8.619	7,2	935	464	8,0	74	9	92	98
29	8.567	7,3	910	436	7,9	93	19	90	96
30	8.218	7,3	902	514	7,9	101	18	89	96
31	9.778								
MED	8.919	7,2	868	422	7,6	81	13	91	97
MIN	7.815	7,0	695	320	7,2	58	7	89	94
MAX	10.568	7,6	985	514	8,0	104	20	93	99
TOTAL	276.498	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Julio'09



Rendimientos EDAR El Torno - Julio'09

