



E.D.A.R. La Barrosa

Febrero'09

	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	14.025	7,6	641	300	7,5	45	7	93	98
2	10.448	7,8	722	360	8,0	54	6	93	98
3	10.106	7,6	858	463	7,5	71	9	92	98
4	10.046	7,8	673	310	7,6	43	6	94	98
5	12.332	7,5	673	265	7,9	51	8	92	97
6	9.384								
7	7.659								
8	6.387	7,7	754	340	7,7	50	8	93	98
9	6.183	7,4	625	280	7,6	35	5	94	98
10	5.876	7,4	609	273	7,4	48	7	92	97
11	5.339	7,3	601	218	7,6	64	11	89	95
12	5.516	7,3	746	328	7,6	48	6	94	98
13	5.339								
14	6.549								
15	5.375	7,4	786	360	7,5	59	10	93	97
16	4.892	7,5	617	260	7,6	56	6	91	98
17	4.915	7,3	689	265	7,4	77	8	89	97
18	4.873	7,3	738	283	7,4	51	5	93	98
19	5.475	7,3	697	250	7,6	52	7	92	97
20	4.758								
21	5.442								
22	5.217	7,5	705	340	7,4	47	6	93	98
23	5.118	7,8	689	320	7,2	63	11	91	97
24	5.256	7,7	842	375	7,4	45	8	95	98
25	4.898	7,6	681	210	7,2	46	6	93	97
26	4.522	7,4	786	356	7,5	42	7	95	98
27	5.059								
28	6.195								
MED	6.685	7,5	707	308	7,5	52	7	93	98
MIN	4.522	7,3	601	210	7,2	35	5	89	95
MAX	14.025	7,8	858	463	8,0	77	11	95	98
TOTAL	187.184	-	-	-	-	-	-	-	-




E.D.A.R. El Torno

Febrero'09

	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	12.084	7,7	645	320	7,4	38	5	94	98
2	11.404	7,6	673	320	8,1	49	10	93	97
3	12.852	7,6	778	367	7,7	82	11	89	97
4	10.951	7,8	585	273	7,8	43	8	93	97
5	10.294	7,5	705	311	8,0	40	7	94	98
6	10.377								
7	10.716								
8	11.127	7,6	850	440	8,0	36	5	96	99
9	10.226	7,4	842	420	7,8	35	10	96	98
10	11.049	7,2	850	394	7,5	44	5	95	99
11	12.400	7,1	649	250	8,4	44	9	93	96
12	11.465	7,3	746	333	8,2	49	7	93	98
13	11.438								
14	10.995								
15	10.525	7,4	842	440	7,9	53	10	94	98
16	11.073	7,5	689	280	8,5	64	11	91	96
17	10.315	7,2	778	320	7,9	65	12	92	96
18	11.291	7,2	786	344	8,2	57	11	93	97
19	10.436	7,1	649	290	8,1	54	13	92	96
20	10.497								
21	11.180								
22	10.335	7,3	867	420	7,8	59	11	93	97
23	10.678	7,0	883	400	7,6	48	8	95	98
24	11.178	7,3	842	393	7,8	38	5	95	99
25	11.184	7,9	931	436	7,9	48	9	95	98
26	11.045	7,1	754	422	7,8	44	12	94	97
27	11.095								
28	9.849								
MED	11.002	7,4	767	359	7,9	50	9	93	97
MIN	9.849	7,0	585	250	7,4	35	5	89	96
MAX	12.852	7,9	931	440	8,5	82	13	96	99
TOTAL	308.057	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Febrero'09



Rendimientos EDAR El Torno - Febrero'09

