


| | Caudal entrada | AGUA BRUTA | | | AGUA TRATADA | | | REND. ELIMINACION | |
|-------|-------------------|------------|--------|---------|--------------|--------|---------|-------------------|---------|
| | | pH | D.Q.O. | D.B.O.5 | pH | D.Q.O. | D.B.O.5 | D.Q.O. | D.B.O.5 |
| Día | m3/día | - | mg/l | mg/l | - | mg/l | mg/l | % | % |
| 1 | 7.673 | 7,3 | 475 | 158 | 7,3 | 15 | 5 | 97 | 97 |
| 2 | 10.334 | | | | | | | | |
| 3 | 11.126 | | | | | | | | |
| 4 | 10.837 | 7,3 | 497 | 240 | 7,5 | 29 | 7 | 94 | 97 |
| 5 | 10.680 | | | | | | | | |
| 6 | 10.820 | 7,5 | 719 | 320 | 7,5 | 53 | 14 | 93 | 96 |
| 7 | 9.292 | | | | | | | | |
| 8 | 9.258 | 7,4 | 676 | 300 | 7,4 | 54 | 14 | 92 | 95 |
| 9 | 8.934 | | | | | | | | |
| 10 | 8.703 | | | | | | | | |
| 11 | 9.824 | 7,2 | 598 | 300 | 7,5 | 71 | 25 | 88 | 92 |
| 12 | 8.523 | 7,4 | 646 | 280 | 7,3 | 44 | 12 | 93 | 96 |
| 13 | 9.546 | 7,4 | 675 | 321 | 7,4 | 67 | 16 | 90 | 95 |
| 14 | 9.570 | 7,7 | 757 | 328 | 7,3 | 84 | 21 | 89 | 94 |
| 15 | 10.244 | 7,6 | 629 | 279 | 7,4 | 45 | 10 | 93 | 96 |
| 16 | 9.110 | | | | | | | | |
| 17 | 8.707 | | | | | | | | |
| 18 | 8.475 | 7,3 | 667 | 280 | 7,4 | 73 | 17 | 89 | 94 |
| 19 | 8.255 | 7,5 | 656 | 320 | 7,5 | 62 | 20 | 91 | 94 |
| 20 | 9.431 | 7,3 | 742 | 260 | 7,5 | 61 | 16 | 92 | 94 |
| 21 | 7.123 | 7,2 | 812 | 346 | 7,4 | 43 | 11 | 95 | 97 |
| 22 | 7.943 | 7,3 | 867 | 419 | 7,4 | 44 | 10 | 95 | 98 |
| 23 | 8.205 | | | | | | | | |
| 24 | 8.830 | | | | | | | | |
| 25 | 6.523 | | | | | | | | |
| 26 | 9.222 | 7,5 | 818 | 360 | 7,5 | 89 | 18 | 89 | 95 |
| 27 | 6.608 | 7,4 | 956 | 400 | 7,5 | 56 | 11 | 94 | 97 |
| 28 | 8.219 | 7,4 | 753 | 352 | 7,4 | 49 | 10 | 94 | 97 |
| 29 | 7.922 | 7,5 | 771 | 344 | 7,6 | 60 | 13 | 92 | 96 |
| 30 | 8.537 | | | | | | | | |
| 31 | 9.598 | | | | | | | | |
| MED | 8.970 | 7,4 | 706 | 311 | 7,4 | 55 | 14 | 92 | 95 |
| MIN | 6.523 | 7,2 | 475 | 158 | 7,3 | 15 | 5 | 88 | 92 |
| MAX | 11.126 | 7,7 | 956 | 419 | 7,6 | 89 | 25 | 97 | 98 |
| TOTAL | 278.072 | - | - | - | - | - | - | - | - |

Rendimientos EDAR El Torno - Diciembre'16



| | Caudal entrada | AGUA BRUTA | | | AGUA TRATADA | | | REND. ELIMINACION | |
|-------|-------------------|------------|--------|---------|--------------|--------|---------|-------------------|---------|
| | | pH | D.Q.O. | D.B.O.5 | pH | D.Q.O. | D.B.O.5 | D.Q.O. | D.B.O.5 |
| Día | m3/día | - | mg/l | mg/l | - | mg/l | mg/l | % | % |
| 1 | 3.074 | 7,6 | 140 | 34 | 7,9 | 15 | 5 | 89 | 85 |
| 2 | 3.576 | | | | | | | | |
| 3 | 10.319 | | | | | | | | |
| 4 | 11.002 | 7,5 | 143 | 60 | 7,6 | 28 | 9 | 81 | 86 |
| 5 | 10.824 | | | | | | | | |
| 6 | 7.978 | 7,4 | 128 | 50 | 7,4 | 26 | 7 | 79 | 87 |
| 7 | 4.841 | | | | | | | | |
| 8 | 3.997 | 7,3 | 422 | 180 | 7,4 | 23 | 6 | 94 | 97 |
| 9 | 3.814 | | | | | | | | |
| 10 | 3.392 | | | | | | | | |
| 11 | 3.048 | 7,8 | 233 | 90 | 7,6 | 20 | 7 | 91 | 92 |
| 12 | 2.700 | 7,8 | 192 | 100 | 7,8 | 21 | 5 | 89 | 95 |
| 13 | 2.842 | 7,7 | 185 | 86 | 7,7 | 27 | 6 | 86 | 93 |
| 14 | 4.526 | 7,3 | 196 | 91 | 7,7 | 25 | 6 | 87 | 94 |
| 15 | 5.113 | 7,6 | 165 | 88 | 7,5 | 29 | 5 | 82 | 94 |
| 16 | 6.760 | | | | | | | | |
| 17 | 3.270 | | | | | | | | |
| 18 | 2.695 | 7,6 | 207 | 120 | 7,3 | 41 | 8 | 80 | 93 |
| 19 | 2.835 | 7,9 | 193 | 140 | 7,8 | 36 | 6 | 81 | 96 |
| 20 | 2.745 | 7,7 | 179 | 80 | 7,7 | 55 | 13 | 69 | 83 |
| 21 | 2.570 | 7,7 | 197 | 90 | 7,6 | 28 | 6 | 86 | 94 |
| 22 | 2.465 | 7,7 | 196 | 109 | 7,5 | 31 | 7 | 84 | 94 |
| 23 | 2.509 | | | | | | | | |
| 24 | 2.471 | | | | | | | | |
| 25 | 2.199 | | | | | | | | |
| 26 | 2.184 | 7,7 | 582 | 240 | 7,4 | 33 | 7 | 94 | 97 |
| 27 | 2.448 | 7,9 | 316 | 180 | 7,6 | 37 | 6 | 88 | 97 |
| 28 | 2.472 | 7,8 | 338 | 148 | 7,7 | 32 | 8 | 91 | 95 |
| 29 | 2.502 | 7,9 | 346 | 179 | 7,7 | 33 | 7 | 90 | 96 |
| 30 | 2.868 | | | | | | | | |
| 31 | 2.748 | | | | | | | | |
| MED | 4.090 | 7,7 | 242 | 115 | 7,6 | 30 | 7 | 86 | 93 |
| MIN | 2.184 | 7,3 | 128 | 34 | 7,3 | 15 | 5 | 69 | 83 |
| MAX | 11.002 | 7,9 | 582 | 240 | 7,9 | 55 | 13 | 94 | 97 |
| TOTAL | 126.787 | - | - | - | - | - | - | - | - |

Rendimientos EDAR La Barrosa - Diciembre'16

