


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	8.427	7,1	711	320	7,9	47	14	93	96
2	8.469	7,5	775	300	7,8	43	11	94	96
3	10.643								
4	6.137								
5	7.428	7,2	621	260	9,0	48	11	92	96
6	7.880	7,2	656	280	8,5	50	12	92	96
7	7.652	7,3	714	320	8,6	56	12	92	96
8	7.926	7,4	644	278	8,5	51	6	92	98
9	7.626								
10	7.482								
11	7.289								
12	7.055	7,5	742	390	8,8	60	17	92	96
13	7.950	7,3	664	320	8,5	59	12	91	96
14	7.966	7,3	644	310	8,5	56	12	91	96
15	7.694	7,3	708	300	8,6	46	8	94	97
16	7.746	7,7	653	265	8,8	43	5	93	98
17	7.737								
18	7.343								
19	7.224	7,6	815	350	7,8	54	11	93	97
20	7.643	7,4	669	320	7,6	43	9	94	97
21	7.333	7,3	667	295	7,4	40	7	94	98
22	7.647	7,1	773	338	7,3	40	7	95	98
23	7.826	7,4	763	331	8,0	54	6	93	98
24	8.218								
25	7.858								
26	7.301	7,6	639	340	8,7	68	11	89	97
27	8.325	7,3	725	400	8,5	43	9	94	98
28	8.620	7,6	717	380	8,7	49	12	93	97
29	9.432	7,3	712	340	8,6	41	11	94	97
30	9.017	7,3	679	360	8,9	42	10	94	97
MED	7.896	7,4	700	324	8,3	49	10	93	97
MIN	6.137	7,1	621	260	7,3	40	5	89	96
MAX	10.643	7,7	815	400	9,0	68	17	95	98
TOTAL	236.894	-	-	-	-	-	-	-	-

### Rendimientos EDAR El Torno - Junio'16



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	6.241	7,6	409	260	7,5	26	8	94	97
2	6.899	7,5	400	200	7,6	24	6	94	97
3	6.926								
4	7.308								
5	7.754	7,4	405	220	7,5	34	8	92	96
6	6.870	7,9	465	210	7,6	33	8	93	96
7	6.403	7,9	456	240	7,7	34	8	92	97
8	7.074	7,3	427	186	7,5	28	3	93	98
9	7.607								
10	7.605								
11	8.441								
12	7.775	7,7	407	300	7,6	32	13	92	96
13	7.912	7,4	349	270	7,4	30	9	91	97
14	7.848	7,5	404	240	7,4	34	9	91	96
15	7.600	7,7	362	200	7,7	36	8	90	96
16	7.127	7,8	507	254	7,7	33	5	93	98
17	7.715								
18	8.678								
19	8.208	7,5	618	300	7,5	33	6	95	98
20	7.777	7,5	395	210	7,5	37	8	91	96
21	7.486	7,4	315	135	7,5	31	4	90	97
22	8.161	7,2	321	130	7,4	32	5	90	96
23	7.945	7,4	353	162	7,5	27	4	92	97
24	9.655								
25	8.946								
26	8.867	7,5	402	220	7,5	30	8	92	96
27	8.548	7,7	590	260	7,7	40	10	93	96
28	8.826	7,8	469	260	7,7	33	11	93	96
29	9.269	7,6	412	240	7,5	31	7	93	97
30	9.157	7,3	420	240	7,3	28	6	93	97
MED	7.888	7,5	423	226	7,5	32	7	92	97
MIN	6.241	7,2	315	130	7,3	24	3	90	96
MAX	9.655	7,9	618	300	7,7	40	13	95	98
TOTAL	236.628	-	-	-	-	-	-	-	-

