


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	10.561	7,3	877	300	7,5	98	5	89	98
2	11.599								
3	10.268								
4	9.085	7,1	1.001	320	7,5	113	23	89	93
5	9.758	7,1	1.084	320	7,4	106	6	90	98
6	9.069	7,1	927	307	7,6	93	5	90	98
7	9.552								
8	9.375	7,2	902	392	7,6	76	9	92	98
9	9.296								
10	8.216								
11	8.545	7,3	902	300	7,3	101	24	89	92
12	9.354	7,2	1.175	320	7,5	106	10	91	97
13	9.171	7,2	885	250	7,5	104	10	88	96
14	8.951	7,2	952	264	7,5	103	4	89	98
15	9.125	7,2	943	314	7,5	109	7	88	98
16	9.650								
17	9.499								
18	8.796	7,4	927	340	7,5	113	18	88	95
19	9.235	7,3	918	300	7,5	111	12	88	96
20	9.338	7,5	918	379	7,5	109	5	88	99
21	9.359	7,3	1.043	450	7,6	113	26	89	94
22	9.427	7,4	952	286	7,7	111	18	88	94
23	9.518								
24	10.219								
25	8.280	7,3	960	320	7,6	109	17	89	95
26	8.985	7,0	1.051	380	7,6	113	13	89	97
27	9.672	7,3	985	300	7,6	108	9	89	97
28	9.593	7,2	1.001	314	7,5	109	5	89	98
29	9.315	7,2	1.001	504	7,5	103	6	90	99
30	9.041								
MED	9.395	7,2	970	333	7,5	105	12	89	96
MIN	8.216	7,0	877	250	7,3	76	4	88	92
MAX	11.599	7,5	1.175	504	7,7	113	26	92	99
TOTAL	281.850	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Septiembre'11



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	12.051	7,4	811	250	7,6	92	4	89	98
2	11.067								
3	10.493								
4	9.224	7,4	935	340	7,9	113	14	88	96
5	9.667	7,3	952	340	7,9	99	17	90	95
6	9.418	7,4	902	279	7,9	72	3	92	99
7	9.436								
8	9.193	7,3	910	300	7,8	96	4	89	99
9	9.701								
10	9.910								
11	9.069	7,4	960	380	7,5	101	13	89	97
12	9.476	7,3	952	420	7,6	104	18	89	96
13	8.525	7,4	927	271	7,7	94	4	90	98
14	8.791	7,6	836	275	7,9	106	5	87	98
15	8.459	7,4	836	338	8,0	100	7	88	98
16	8.610								
17	8.984								
18	8.966	7,6	902	420	8,1	91	11	90	97
19	8.523	7,4	852	340	7,7	99	15	88	96
20	7.144	7,5	695	250	7,7	100	2	86	99
21	7.966	7,4	918	307	8,1	100	4	89	99
22	7.520	7,5	852	294	7,8	104	5	88	98
23	7.825								
24	8.059								
25	8.010	7,5	976	360	7,9	100	8	90	98
26	7.597	7,4	885	340	7,8	105	24	88	93
27	7.391	7,6	885	306	8,2	99	10	89	97
28	7.427	7,6	894	307	7,5	100	6	89	98
29	7.477	7,6	968	536	7,7	103	3	89	99
30	7.676								
MED	8.789	7,4	892	333	7,8	99	9	89	97
MIN	7.144	7,3	695	250	7,5	72	2	86	93
MAX	12.051	7,6	976	536	8,2	113	24	92	99
TOTAL	263.655	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Septiembre'11

