


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	9.769								
2	10.243								
3	9.387	7,7	1.059	320	7,8	117	11	89	97
4	10.376	7,7	1.125	460	7,7	93	24	92	95
5	9.889	7,8	918	340	7,6	119	37	87	89
6	9.974	7,6	1.067	508	7,9	109	18	90	96
7	9.292	7,5	1.134	633	7,7	111	25	90	96
8	10.308								
9	9.598								
10	9.445	7,1	1.018	300	6,7	114	13	89	96
11	10.124	7,2	935	340	7,7	101	3	89	99
12	10.157	7,2	869	294	8,0	109	6	87	98
13	9.871	6,6	1.010	364	6,5	106	8	90	98
14	10.564	7,1	902	264	7,0	101	17	89	94
15	10.249								
16	10.964								
17	9.769	6,5	662	300	6,7	111	10	83	97
18	9.379	6,9	877	300	6,8	101	13	88	96
19	10.836	7,3	869	244	7,1	93	15	89	94
20	10.040								
21	9.836								
22	10.149								
23	10.852								
24	11.045	7,4	894	300	7,3	104	14	88	95
25	11.051	7,4	902	360	7,1	114	29	87	92
26	10.539	7,5	844	256	7,4	98	23	88	91
27	10.589	7,4	3.508	283	7,1	93	18	97	94
28	10.085	7,3	836	306	7,3	86	20	90	93
29	9.876								
30	10.956								
MED	10.174	7,3	1.079	343	7,3	104	17	89	95
MIN	9.292	6,5	662	244	6,5	86	3	83	89
MAX	11.051	7,8	3.508	633	8,0	119	37	97	99
TOTAL	305.215	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Abril'11



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	5.743								
2	6.389								
3	5.987	7,7	811	320	8,2	104	5	87	98
4	5.657	7,7	918	360	8,0	102	11	89	97
5	5.442	7,6	910	550	7,7	87	16	90	97
6	5.123	7,8	786	319	7,8	96	13	88	96
7	5.685	7,6	786	319	8,1	84	9	89	97
8	5.962								
9	6.499								
10	6.244	7,1	662	340	8,0	83	11	87	97
11	6.011	7,2	1.043	340	7,8	73	5	93	99
12	5.771	7,2	728	261	8,5	89	7	88	97
13	5.588	6,9	836	263	7,1	94	12	89	96
14	6.241	7,3	819	338	7,9	100	10	88	97
15	6.271								
16	7.024								
17	7.122	6,5	869	340	6,9	78	16	91	95
18	7.456	7,0	844	320	6,8	95	10	89	97
19	8.122	7,3	794	231	7,5	102	19	87	92
20	7.723								
21	10.806								
22	12.071								
23	12.270								
24	8.756	7,5	861	320	7,7	97	9	89	97
25	7.652	7,4	952	440	7,8	107	15	89	97
26	6.323	7,5	877	400	7,6	90	11	90	97
27	5.952	7,2	778	400	7,4	96	10	88	98
28	5.968	7,2	869	413	7,3	91	13	89	97
29	9.870								
30	8.965								
MED	7.156	7,3	841	349	7,7	93	11	89	97
MIN	5.123	6,5	662	231	6,8	73	5	87	92
MAX	12.270	7,8	1.043	550	8,5	107	19	93	99
TOTAL	214.693	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Abril'11

