


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	10.943	7,4	1.043	460	7,5	104	10	90	98
2	9.853	7,8	968	513	7,9	104	14	89	97
3	10.393	7,2	4.171	342	7,4	103	8	98	98
4	10.977								
5	9.859								
6	9.813	7,5	1.001	480	7,7	111	2	89	100
7	9.897	7,4	985	420	7,3	109	12	89	97
8	10.480	7,3	836	463	7,1	108	25	87	95
9	14.133	7,6	960	579	7,8	103	12	89	98
10	11.932	7,6	827	419	7,6	106	17	87	96
11	15.242								
12	13.003								
13	7.262	7,9	637	220	7,8	94	7	85	97
14	11.109	8,3	836	360	8,0	93	17	89	95
15	11.342	8,0	1.125	700	8,0	108	32	90	95
16	13.419	8,1	794	343	8,0	98	22	88	94
17	11.087	7,8	960	421	7,8	104	13	89	97
18	11.081								
19	11.332								
20	9.718	8,0	960	320	7,7	103	11	89	97
21	11.350	7,2	1.043	500	7,7	114	19	89	96
22	9.760	7,1	1.125	708	7,6	101	25	91	96
23	10.596	7,4	1.080	667	7,6	86	21	92	97
24	10.595	7,6	960	400	7,9	89	23	91	94
25	10.248								
26	9.847								
27	9.906	7,5	852	440	7,7	93	2	89	100
28	11.110	7,7	960	460	7,7	98	28	90	94
29	10.210	7,6	1.873	338	7,7	96	14	95	96
30	9.953	7,8	902	407	7,6	88	10	90	98
31	9.988	8,1	861	388	8,1	108	23	88	94
MED	10.853	7,6	1.120	450	7,7	101	16	90	96
MIN	7.262	7,1	637	220	7,1	86	2	85	94
MAX	15.242	8,3	4.171	708	8,1	114	32	98	100
TOTAL	336.441	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Marzo'11



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	5.128	7,6	894	340	8,0	97	8	89	98
2	4.846	7,8	960	406	7,9	102	5	89	99
3	4.501	7,4	819	294	7,5	97	4	88	99
4	5.388								
5	5.622								
6	5.365	7,6	720	340	7,8	79	11	89	97
7	5.169	7,5	794	360	7,8	103	6	87	98
8	10.903	7,3	811	419	7,2	101	16	88	96
9	8.617	7,7	662	200	7,7	96	5	86	98
10	6.745	7,6	587	159	8,2	91	12	85	92
11	8.799								
12	7.079								
13	8.241	7,7	612	260	7,9	86	13	86	95
14	10.974	7,9	703	320	7,8	87	6	88	98
15	8.432	7,9	678	230	8,0	103	8	85	97
16	5.923	7,9	703	200	7,9	102	14	86	93
17	5.973	7,8	960	600	8,0	105	13	89	98
18	6.070								
19	6.072								
20	5.727	7,8	894	380	7,9	108	9	88	98
21	5.789	7,6	637	280	7,7	106	9	83	97
22	6.226	7,7	877	531	8,0	103	4	88	99
23	5.658	7,7	910	414	8,0	95	13	90	97
24	5.309	7,5	794	406	7,6	100	9	87	98
25	5.189								
26	5.531								
27	5.794	7,6	819	300	8,0	91	7	89	98
28	5.242	7,6	869	360	8,0	91	12	89	97
29	5.349	7,6	877	419	7,9	96	10	89	98
30	5.654	7,4	861	363	7,9	86	10	90	97
31	5.812	7,8	943	471	8,2	94	12	90	97
MED	6.359	7,6	799	350	7,9	96	9	88	97
MIN	4.501	7,3	587	159	7,2	79	4	83	92
MAX	10.974	7,9	960	600	8,2	108	16	90	99
TOTAL	197.127	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Marzo'11

