


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	10.336	7,6	815	380	7,5	98	17	88	96
2	10.246	7,4	949	364	7,3	87	13	91	96
3	7.516	7,2	563	198	7,3	65	12	88	94
4	12.606	7,1	377	120	7,2	60	10	84	92
5	12.358								
6	12.519								
7	10.878	7,4	979	440	7,2	98	43	90	90
8	9.851	7,4	964	420	7,5	75	35	92	92
9	9.821	7,4	875	189	7,6	75	9	91	95
10	9.644	7,3	964	216	7,5	83	19	91	91
11	9.497	7,4	823	422	7,9	63	5	92	99
12	9.339								
13	9.587								
14	7.406	7,3	726	500	7,6	77	37	89	93
15	9.154	7,2	659	400	7,3	99	16	85	96
16	9.131	7,2	994	374	7,7	89	17	91	95
17	9.162	7,5	681	256	7,9	89	17	87	93
18	9.186	7,3	815	298	7,3	80	16	90	95
19	9.548								
20	9.247								
21	8.538								
22	8.310	6,9	1.083	620	7,1	71	30	93	95
23	8.632	7,2	1.016	520	7,3	69	15	93	97
24	8.665	7,3	1.105	472	7,0	69	15	94	97
25	8.897	7,5	800	439	7,4	111	17	86	96
26	9.242								
27	8.747								
28	8.793	7,7	867	620	7,4	40	24	95	96
29	9.268	7,1	971	460	7,4	92	21	91	95
30	10.889								
MED	9.567	7,3	851	385	7,4	79	19	90	95
MIN	7.406	6,9	377	120	7,0	40	5	84	90
MAX	12.606	7,7	1.105	620	7,9	111	43	95	99
TOTAL	287.013	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Abril'13



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	7.834	7,7	399	260	7,9	72	14	82	95
2	6.530	7,6	615	181	7,6	70	4	89	98
3	9.926	7,7	236	74	7,3	51	7	78	90
4	14.190	7,2	198	67	7,5	56	5	72	93
5	11.590								
6	8.360								
7	6.580	7,6	570	200	7,5	72	15	87	92
8	6.345	7,9	369	160	7,6	58	9	84	94
9	5.507	7,6	466	148	7,6	54	3	88	98
10	5.659	7,4	496	100	7,7	65	9	87	91
11	5.181	7,6	325	105	7,8	48	13	85	88
12	5.791								
13	5.681								
14	5.805	7,6	325	160	7,5	78	17	76	89
15	5.280	7,3	526	240	7,3	82	12	84	95
16	5.253	7,4	325	116	8,2	75	9	77	92
17	5.254	7,8	332	125	7,9	60	9	82	93
18	5.497	7,8	340	99	7,2	61	13	82	86
19	6.107								
20	6.704								
21	6.234								
22	5.740	7,2	474	220	7,1	65	25	86	89
23	5.396	7,6	459	240	7,3	66	20	86	92
24	5.030	7,3	548	264	7,0	54	8	90	97
25	5.208	7,5	474	257	7,7	82	16	83	94
26	5.704								
27	6.033								
28	5.595	7,4	645	280	7,2	71	17	89	94
29	6.764	7,7	414	220	7,7	73	13	82	94
30	5.952								
MED	6.558	7,5	427	176	7,5	66	12	84	93
MIN	5.030	7,2	198	67	7,0	48	3	72	86
MAX	14.190	7,9	645	280	8,2	82	25	90	98
TOTAL	196.730	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Abril'13

