


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	10.909	7,3	927	421	7,3	99	28	89	93
2	8.604	7,1	2.082	500	7,5	97	26	95	95
3	8.455	7,4	711	306	7,4	95	15	87	95
4	8.762								
5	8.750								
6	7.426								
7	8.248	7,4	652	320	7,4	60	17	91	95
8	8.448	7,3	934	360	7,5	74	16	92	96
9	8.946	7,2	808	370	7,2	89	18	89	95
10	8.630	7,2	852	273	7,2	89	10	90	96
11	9.000								
12	8.795								
13	9.228	7,5	815	560	7,4	96	17	88	97
14	8.143	7,1	726	400	7,6	84	20	88	95
15	8.216	7,5	778	256	7,1	95	10	88	96
16	7.992	7,6	867	301	7,8	93	12	89	96
17	7.844	7,3	912	500	7,2	98	22	89	96
18	8.633								
19	7.354								
20	7.720	7,6	897	520	7,4	99	7	89	99
21	11.067	7,5	845	280	7,4	84	8	90	97
22	11.177	7,3	860	592	7,5	87	32	90	95
23	8.453	7,4	905	491	7,3	86	17	91	97
24	9.313	7,4	622	208	7,1	95	20	85	90
25	9.545								
26	10.197								
27	8.349	7,2	808	460	7,2	81	21	90	95
28	9.257	7,3	852	400	7,3	98	13	89	97
29	9.280	7,4	845	218	7,1	92	13	89	94
30	9.070	7,3	912	254	7,4	87	20	90	92
31	8.785	7,1	875	234	6,8	80	21	91	91
MED	8.858	7,3	886	374	7,3	89	17	89	95
MIN	7.354	7,1	622	208	6,8	60	7	85	90
MAX	11.177	7,6	2.082	592	7,8	99	32	95	99
TOTAL	274.597	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Enero'13



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	4.472	7,6	481	107	7,4	44	4	91	96
2	3.600	7,5	289	190	7,6	28	12	90	94
3	3.568	7,3	466	164	7,3	44	5	91	97
4	3.470								
5	3.383								
6	3.079								
7	3.479	7,4	935	240	7,8	22	5	98	98
8	3.558	7,6	466	220	7,9	56	9	88	96
9	3.484	7,5	451	129	7,8	55	10	88	92
10	3.168	7,5	384	150	7,1	56	12	86	92
11	3.406								
12	3.840								
13	5.165	7,4	607	180	7,9	72	4	88	98
14	3.510	7,5	451	240	7,4	62	10	86	96
15	3.398	7,5	474	99	7,1	60	2	87	98
16	3.337	7,8	630	77	8,0	66	3	90	97
17	3.159	7,4	518	225	7,1	56	13	89	94
18	3.880								
19	8.037								
20	7.523	7,9	890	260	7,4	65	17	93	93
21	6.318	7,6	347	220	7,5	29	9	92	96
22	5.118	7,4	347	261	7,8	49	5	86	98
23	4.347	7,4	481	182	7,6	61	9	87	95
24	4.096	7,4	280	60	7,2	47	6	83	90
25	7.028								
26	4.609								
27	3.967	7,5	384	220	7,3	61	8	84	96
28	3.991	7,4	436	200	7,1	58	5	87	97
29	3.784	7,5	384	153	7,3	44	2	89	99
30	3.891	7,6	436	164	7,5	53	6	88	96
31	3.614	7,2	414	277	7,0	36	8	91	97
MED	4.235	7,5	480	183	7,5	51	8	89	96
MIN	3.079	7,2	280	60	7,0	22	2	83	90
MAX	8.037	7,9	935	277	8,0	72	17	98	99
TOTAL	131.279	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Enero'13

