


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	8.088								
2	7.885								
3	7.885	7,1	867	500	7,3	86	16	90	97
4	8.276	7,2	957	640	7,5	72	8	92	99
5	8.409	7,1	942	291	7,4	78	7	92	98
6	8.551	7,2	979	283	7,4	83	3	92	99
7	8.395	7,0	830	317	7,5	65	11	92	97
8	8.657								
9	8.141								
10	7.381	7,3	965	600	7,3	83	15	91	98
11	8.424	7,3	897	380	7,2	86	16	90	96
12	8.305	7,3	823	135	7,6	87	5	89	96
13	8.469	7,1	808	298	7,4	93	10	88	97
14	8.495	7,6	875	412	7,5	93	13	89	97
15	8.670								
16	8.080								
17	7.690	7,3	607	420	7,6	84	6	86	99
18	8.533	7,4	845	440	7,5	69	12	92	97
19	8.416	7,2	845	377	7,3	69	2	92	99
20	8.504	7,1	577	256	7,3	63	2	89	99
21	8.551	7,2	756	311	7,5	89	15	88	95
22	9.762								
23	9.062								
24	8.007	7,4	771	400	7,1	87	11	89	97
25	8.871	7,4	1.016	320	7,3	74	11	93	97
26	8.475	7,6	815	256	7,8	86	7	89	97
27	8.628	7,5	979	475	7,5	83	14	92	97
28	8.530	7,5	890	237	7,3	86	6	90	97
29	9.275								
30	8.661								
MED	8.436	7,3	852	367	7,4	81	10	90	97
MIN	7.381	7,0	577	135	7,1	63	2	86	95
MAX	9.762	7,6	1.016	640	7,8	93	16	93	99
TOTAL	253.076	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Noviembre'13



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	3.805								
2	5.436								
3	4.813	7,3	615	180	7,1	63	12	90	93
4	4.761	7,4	570	300	7,6	57	8	90	97
5	4.528	7,2	756	172	7,2	74	4	90	98
6	4.007	7,3	630	104	7,7	81	3	87	97
7	3.843	7,3	384	183	7,7	41	6	89	97
8	4.192								
9	3.990								
10	4.009	7,3	935	280	7,7	74	9	92	97
11	4.001	7,3	488	320	7,6	58	5	88	98
12	4.403	7,3	481	172	7,6	47	3	90	98
13	4.025	7,3	719	104	7,5	46	3	94	97
14	3.830	7,5	533	142	7,8	60	2	89	99
15	4.075								
16	3.303								
17	3.650	7,4	392	260	7,5	53	13	86	95
18	3.514	7,4	459	340	7,7	58	15	87	96
19	3.507	7,5	459	144	7,3	51	5	89	96
20	3.796	7,5	355	63	7,7	61	6	83	90
21	3.643	7,5	533	254	7,7	45	3	92	99
22	5.766								
23	5.773								
24	3.533	7,5	555	260	7,0	65	21	88	92
25	3.460	7,5	845	320	7,3	72	17	91	95
26	3.579	7,7	786	121	7,8	80	4	90	97
27	3.344	7,7	682	188	7,3	81	19	88	90
28	3.412	7,5	719	113	7,5	51	2	93	98
29	3.659								
30	3.498								
MED	4.039	7,4	574	212	7,5	61	8	89	96
MIN	3.303	6,9	305	87	7,0	41	2	83	90
MAX	5.773	7,8	749	340	7,8	81	21	94	99
TOTAL	121.155	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Noviembre13

