


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	8.370	7,5	748	308	7,6	43	12	94	96
2	9.026								
3	8.145								
4	7.828	7,2	687	300	7,2	52	5	92	98
5	8.456	7,2	799	260	7,2	41	8	95	97
6	8.584	7,4	798	304	7,6	50	4	94	99
7	8.038	7,8	776	155	7,8	48	4	94	97
8	8.095								
9	8.062								
10	7.742								
11	7.892	6,9	643	480	7,3	34	13	95	97
12	8.281	7,4	788	500	7,8	36	14	95	97
13	8.499	7,0	822	375	7,4	40	6	95	98
14	8.485	7,3	693	397	7,5	46	4	93	99
15	8.489	7,2	766	379	7,4	40	6	95	98
16	8.788								
17	7.983								
18	7.691	7,2	675	400	7,8	41	11	94	97
19	8.316	7,2	647	440	7,4	38	12	94	97
20	7.683	7,2	645	429	7,7	38	4	94	99
21	9.522	7,2	595	310	7,3	42	5	93	98
22	8.457	7,5	592	354	7,7	35	5	94	99
23	9.130								
24	7.745								
25	8.009	7,2	609	480	7,6	42	12	93	98
26	8.475	7,5	728	440	7,9	47	9	94	98
27	8.264	7,4	913	483	7,5	60	13	93	97
28	8.034	7,0	594	313	7,5	50	7	92	98
29	8.062	7,2	577	309	7,5	43	6	93	98
30	8.281								
MED	8.281	7,3	705	371	7,5	43	8	94	98
MIN	7.683	6,9	577	155	7,2	34	4	92	96
MAX	9.522	7,8	913	500	7,9	60	14	95	99
TOTAL	248.432	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Junio'17



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	6.577	7,6	825	326	7,8	36	8	96	98
2	7.704								
3	8.033								
4	7.594	7,1	1.160	380	7,2	40	3	97	99
5	6.920	7,3	1.086	480	7,0	37	4	97	99
6	6.554	7,4	1.179	413	7,5	40	5	97	99
7	7.499	7,8	1.350	370	7,7	38	2	97	99
8	6.480								
9	7.283								
10	7.557								
11	6.561	7,1	1.336	640	7,4	38	14	97	98
12	6.429	7,6	429	380	8,0	32	12	93	97
13	7.887	7,1	1.157	413	7,4	39	4	97	99
14	7.099	7,4	1.180	533	7,6	45	4	96	99
15	7.842	7,4	862	383	7,6	33	4	96	99
16	8.420								
17	8.382								
18	8.873	7,5	769	480	7,8	53	17	93	97
19	7.926	7,2	499	260	7,2	42	15	92	94
20	7.953	7,1	516	295	7,8	59	9	88	97
21	7.645	7,2	459	186	7,5	34	3	93	98
22	7.430	7,6	420	164	7,8	35	3	92	98
23	8.109								
24	8.963								
25	9.112	7,2	506	420	7,3	42	11	92	97
26	9.018	7,5	594	300	7,8	37	9	94	97
27	8.662	7,4	787	309	7,4	41	5	95	98
28	7.506	7,2	464	265	7,2	55	12	88	95
29	8.464	7,4	782	212	7,4	35	3	96	99
30	8.974								
MED	7.782	7,4	818	360	7,5	41	7	94	98
MIN	6.429	7,1	420	164	7,0	32	2	88	94
MAX	9.112	7,8	1.350	640	8,0	59	17	97	99
TOTAL	233.456	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Junio'17

