


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	8.654								
2	8.513								
3	9.040	7,2	570	180	7,6	39	6	93	97
4	10.508	7,1	419	105	7,1	69	12	84	89
5	9.629								
6	7.223	7,5	445	122	7,9	40	11	91	91
7	8.076	7,1	445	125	7,1	40	10	91	92
8	10.533								
9	8.682								
10	7.786	7,4	618	212	7,7	50	13	92	94
11	8.558	7,2	404	120	7,2	43	9	89	93
12	8.604	7,8	562	178	7,4	61	13	89	93
13	8.501	7,2	612	236	7,3	46	9	92	96
14	8.540	7,2	474	101	7,4	71	14	85	86
15	8.410								
16	7.711								
17	7.414	7,0	876	305	7,2	36	7	96	98
18	8.195	7,8	579	156	7,6	26	5	96	97
19	8.748	6,9	760	263	7,5	33	8	96	97
20	8.470	7,0	525	165	7,7	38	14	93	92
21	8.185	6,6	870	273	7,7	30	6	97	98
22	8.092								
23	8.105								
24	7.614	7,4	720	277	7,1	62	11	91	96
25	8.332	6,4	720	248	6,7	43	10	94	96
26	8.139	7,0	710	296	7,4	28	9	96	97
27	8.205	7,2	1.010	304	7,5	48	11	95	96
28	7.902	6,5	700	256	7,7	34	6	95	98
29	7.882								
30	7.712								
31	7.441	6,8	900	318	7,2	40	7	96	98
MED	8.368	7,1	646	212	7,4	44	10	93	95
MIN	7.223	6,4	404	101	6,7	26	5	84	86
MAX	10.533	7,8	1.010	318	7,9	71	14	97	98
TOTAL	259.404	-	-	-	-	-	-	-	-

## Rendimientos EDAR El Torno - Enero '16



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	4.144								
2	4.191								
3	3.361	7,1	414	130	7,7	21	8	95	94
4	7.905	7,3	457	136	7,3	23	9	95	93
5	8.445								
6	4.978	7,5	211	85	7,4	12	5	95	94
7	5.726	7,3	211	89	7,4	12	5	95	94
8	6.598								
9	5.057								
10	3.020	7,2	392	101	7,2	16	5	96	95
11	5.785	7,2	235	98	7,0	15	5	94	95
12	4.566	7,7	220	98	7,5	44	12	80	88
13	4.781	7,1	192	88	7,4	23	9	88	90
14	4.570	7,9	209	102	7,6	31	13	85	87
15	4.774								
16	4.815								
17	4.258	7,3	166	77	7,3	29	11	83	86
18	4.707	7,5	164	74	7,4	30	12	81	84
19	3.089	7,2	140	30	7,0	15	5	89	83
20	4.141	7,4	146	54	7,1	15	6	90	89
21	3.029	6,8	140	34	6,8	15	5	89	85
22	2.945								
23	2.885								
24	2.913	7,3	450	112	7,2	15	5	97	96
25	2.998	6,8	184	52	6,5	22	5	88	90
26	3.551	7,3	250	69	7,0	16	5	94	93
27	3.044	7,6	380	158	7,1	16	5	96	97
28	2.944	6,9	196	52	6,7	15	5	92	90
29	3.347								
30	3.359								
31	3.083	7,1	300	88	7,1	15	5	95	94
MED	4.291	7,3	253	86	7,2	20	7	91	91
MIN	2.885	6,8	140	30	6,5	12	5	80	83
MAX	8.445	7,9	457	158	7,7	44	13	97	97
TOTAL	133.009	-	-	-	-	-	-	-	-

## Rendimientos EDAR La Barrosa - Enero '16

