


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	8.302	7,2	631	224	7,8	50	14	92	94
2	8.242	7,2	774	320	7,7	48	5	94	98
3	8.298	7,0	821	280	7,7	48	6	94	98
4	8.188								
5	7.862								
6	7.648	7,2	672	215	8,6	54	18	92	92
7	8.974	7,4	561	216	7,6	59	14	89	94
8	8.433	7,5	648	120	7,9	62	3	90	97
9	8.279	7,7	666	132	8,4	97	23	85	83
10	8.226	7,4	724	212	7,4	48	8	93	96
11	8.639								
12	7.877								
13	7.478	7,3	630	480	7,4	56	1	91	100
14	8.276	7,6	873	280	7,7	76	2	91	99
15	8.112	7,4	1.040	383	8,3	55	9	95	98
16	8.272	7,3	691	291	7,6	59	16	91	95
17	8.296	7,4	456	276	8,2	49	9	89	97
18	10.197								
19	8.803								
20	9.095	7,5	598	200	7,5	50	20	92	90
21	8.989	7,3	1.332	440	7,6	56	5	96	99
22	9.106	7,4	724	268	7,6	64	5	91	98
23	8.580								
24	5.069								
25	11.000								
26	7.791								
27	7.574	7,6	597	400	9,0	49	3	92	99
28	8.783	7,5	1.000	128	9,2	47	7	95	95
29	8.330	7,5	763	318	8,6	51	6	93	98
30	8.143	7,4	732	212	8,8	50	4	93	98
31	7.971								
MED	8.349	7,4	747	270	8,0	56	9	92	96
MIN	5.069	7,0	456	120	7,4	47	1	85	83
MAX	11.000	7,7	1.332	480	9,2	97	23	96	100
TOTAL	258.833	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Marzo '16



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	3.033	7,8	232	152	6,9	33	12	86	92
2	3.372	7,7	210	120	7,1	24	6	89	95
3	2.898	7,7	223	120	7,1	22	5	90	96
4	3.628								
5	3.269								
6	3.072	7,9	318	200	7,3	34	17	89	91
7	3.651	7,7	257	144	7,1	25	4	90	97
8	3.649	7,7	204	55	7,5	40	4	80	93
9	3.310	7,9	351	151	7,4	35	4	90	97
10	3.648	7,0	576	250	7,3	42	4	93	98
11	3.801								
12	3.615								
13	3.562	7,5	227	20	7,3	35	5	85	76
14	3.587	7,7	215	40	7,1	21	1	90	97
15	3.149	7,8	357	139	7,0	26	2	93	99
16	3.193	8,2	240	80	7,3	20	3	92	97
17	3.527	7,8	216	72	7,0	14	2	94	98
18	5.463								
19	6.262								
20	4.334	7,5	369	140	7,3	26	6	93	95
21	4.497	7,6	343	200	7,1	35	1	90	99
22	6.014	7,4	316	152	7,2	32	3	90	98
23	4.912								
24	5.394								
25	5.681								
26	5.550								
27	5.694	7,8	375	260	7,3	43	11	88	96
28	4.412	7,9	376	180	7,5	28	1	92	99
29	4.696	7,7	349	145	7,5	29	2	92	99
30	4.229	7,9	399	162	7,5	35	1	91	99
31	3.832								
MED	4.159	7,7	308	139	7,2	30	5	90	96
MIN	2.898	7,0	204	20	6,9	14	1	80	76
MAX	6.262	8,2	576	260	7,5	43	17	94	99
TOTAL	128.934	-	-	-	-	-	-	-	-

