


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	8.057	6,8	670	216	7,3	35	12	95	94
2	8.009	7,2	670	166	7,5	37	10	94	94
3	7.912	7,0	640	202	7,5	47	10	93	95
4	8.030	6,9	700	212	7,5	48	9	93	96
5	8.140								
6	8.771								
7	7.973	7,0	700	192	7,4	61	17	91	91
8	7.973	6,7	840	325	7,1	17	17	98	95
9	8.924	7,0	600	184	7,3	15	5	98	97
10	9.917	6,8	485	143	7,1	49	15	90	90
11	8.602	6,6	325	78	7,1	44	14	86	82
12	8.666								
13	9.937								
14	7.832	7,1	490	146	7,6	17	8	97	95
15	8.950	6,6	510	182	7,0	15	6	97	96
16	8.256	7,0	310	80	7,5	65	15	79	81
17	9.882	7,0	305	86	7,6	15	6	95	93
18	8.697	6,8	420	134	7,4	15	5	96	96
19	8.312								
20	8.451								
21	7.388	7,2	750	244	7,3	15	5	98	98
22	8.337	7,1	710	227	8,7	58	9	92	96
23	8.310	7,0	720	248	8,0	56	9	92	96
24	8.568	6,8	690	206	7,3	61	13	80	85
25	8.123								
26	8.591								
27	7.846								
28	7.392								
29	7.581	7,0	600	171	7,6	39	8	94	95
MED	8.394	6,9	586	181	7,5	37	10	93	93
MIN	7.388	6,6	305	78	7,0	15	5	79	81
MAX	9.937	7,2	840	325	8,7	65	17	98	98
TOTAL	243.427	-	-	-	-	-	-	-	-

### Rendimientos EDAR El Torno - Febrero '16



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	3.086	7,1	425	130	6,9	15	6	96	96
2	3.430	7,4	285	77	7,2	18	6	94	92
3	2.724	7,2	280	54	6,9	15	5	95	91
4	3.097	7,2	370	96	7,0	15	5	96	95
5	3.037								
6	3.263								
7	3.349	7,3	355	72	6,9	15	6	96	91
8	3.364	7,1	310	92	6,6	15	5	95	94
9	3.920	7,2	142	46	7,0	15	5	89	89
10	4.506	7,2	300	64	6,9	15	5	95	92
11	7.328	6,9	146	44	6,5	15	5	90	89
12	3.433								
13	4.873								
14	4.500	7,2	60	60	7,2	15	5	75	92
15	4.041	6,7	46	17	6,7	15	5	67	71
16	3.259	7,1	75	19	7,1	15	5	80	74
17	3.515	7,1	40	12	7,1	15	5	63	58
18	4.562	7,0	40	15	7,0	15	5	63	67
19	3.165								
20	3.616								
21	3.200	7,4	260	57	7,2	15	5	94	91
22	3.540	7,1	475	129	7,2	21	5	96	96
23	3.517	7,3	280	101	7,0	25	5	91	95
24	3.902	7,3	320	78	6,9	15	5	94	95
25	4.849								
26	10.340								
27	4.120								
28	3.541								
29	3.514	7,5	305	77	7,0	15	5	95	94
MED	4.020	7,2	238	65	7,0	16	5	88	87
MIN	2.724	6,7	40	12	6,5	15	5	63	58
MAX	10.340	7,5	475	130	7,2	25	6	96	96
TOTAL	116.591	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Febrero '16

