


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	7.811	7,1	890	600	6,9	95	40	89	93
2	8.454	7,0	726	320	7,2	95	10	87	97
3	8.375	7,1	778	293	7,2	93	12	88	96
4	8.622	7,1	890	480	7,6	84	20	91	96
5	8.379	7,1	793	421	7,9	75	10	91	98
6	9.054								
7	8.095								
8	7.665	7,2	734	460	7,9	71	16	90	97
9	8.507	7,3	852	420	8,1	108	3	87	99
10	8.482	7,1	756	391	8,2	50	2	93	99
11	8.903	7,4	786	301	7,8	78	6	90	98
12	9.017								
13	8.562								
14	8.513								
15	8.261	7,2	793	460	7,8	93	16	88	97
16	8.826	7,2	830	520	7,8	89	11	89	98
17	8.684	7,2	823	320	7,9	84	9	90	97
18	8.655	7,3	1.157	340	8,1	87	4	92	99
19	8.553	7,3	957	323	7,6	72	3	92	99
20	8.890								
21	8.199								
22	7.699	7,2	800	680	7,9	89	10	89	99
23	8.442	7,1	815	540	7,9	95	20	88	96
24	10.008	7,1	778	365	7,9	93	8	88	98
25	8.788	7,2	623		7,9	56		91	
26	8.932	7,0	685		7,5	30		96	
27	8.908								
28	8.471								
29	7.860	7,3	734	520	7,4	81	17	89	97
30	8.352	7,2	823	480	7,6	80	22	90	95
31									
MED	8.532	7,2	811	433	7,7	81	13	90	97
MIN	7.665	7,0	623	293	6,9	30	2	87	93
MAX	10.008	7,4	1.157	680	8,2	108	40	96	99
TOTAL	255.967	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Junio'12



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	6.209	7,3	600	360	7,3	82	17	86	95
2	5.544	7,4	630	260	7,2	65	19	90	93
3	5.725	7,4	600	222	7,2	71	10	88	95
4	5.169	7,4	607	249	7,1	86	13	86	95
5	5.415	7,3	496	168	7,1	60	5	88	97
6	5.768								
7	6.313								
8	5.846	7,3	511	320	6,9	66	23	87	93
9	5.888	7,6	719	260	7,1	90	34	87	87
10	5.833	7,4	607	212	7,0	31	3	95	99
11	5.777	7,2	607	276	7,1	49	14	92	95
12	5.900								
13	6.360								
14	7.756								
15	6.944	7,5	793	360	7,5	66	22	92	94
16	6.512	7,4	756	420	7,4	141	21	81	95
17	6.244	7,5	674	159	7,5	93	10	86	93
18	6.042	7,7	674	147	7,6	82	4	88	97
19	6.272	7,4	578	99	7,0	57	6	90	94
20	6.093								
21	7.271								
22	7.023	7,4	719	420	7,5	82	19	89	96
23	6.639	7,4	645	340	7,2	72	31	89	91
24	7.048	7,5	481	175	6,9	69	3	86	98
25	6.075	7,6	399		7,4	16		96	
26	5.895	7,5	690		7,9	48		93	
27	6.214								
28	8.125								
29	7.860	7,5	459	300	7,3	74	18	84	94
30	7.250	7,4	689	360	7,0	69	14	90	96
31	#¡REF!								
MED	#¡REF!	7,4	616	269	7,3	70	15	89	95
MIN	#¡REF!	7,2	399	99	6,9	16	3	81	87
MAX	#¡REF!	7,7	793	420	7,9	141	34	96	99
TOTAL	#¡REF!	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Junio'12

