


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	6.293								
2	7.227	7,2	964	540	8,1	77	16	92	97
3	10.108	7,2	964	500	8,0	72	19	92	96
4	8.974	7,3	726	297	8,0	63	8	91	97
5	8.360	7,6	719	345	7,5	66	3	91	99
6	9.223	7,4	644	264	8,7	78	6	88	98
7	10.009								
8	8.902								
9	7.803	7,6	734	420	7,3	81	16	89	96
10	9.433	7,5	637	360	7,8	77	36	88	90
11	9.778	7,3	667	215	7,4	81	10	88	95
12	9.624	7,3	838	356	7,3	75	7	91	98
13	11.372	7,4	719	178	7,8	74	8	90	96
14	11.611								
15	8.772								
16	7.667	7,6	719	480	7,2	63	7	91	99
17	8.357	7,4	793	480	8,1	66	8	92	98
18	8.026	7,6	659	421	7,7	58	14	91	97
19	8.206	7,5	667	230	8,2	69	15	90	93
20	8.001	7,4	865	271	8,2	67	15	92	94
21	8.400								
22	7.453								
23	10.252	7,6	601	340	7,8	80	25	87	93
24	8.783	7,4	466	187	7,5	71	9	90	97
25	8.393	7,0	672	127	7,3	65	7	85	95
26	11.133	7,1	594	76	7,4	71	9	90	94
27	11.468	7,1	594	76	7,4	71	9	88	88
28	12.662								
29	11.511								
30	10.112	7,7	710	320	7,6	69	16	90	95
31									
MED	9.264	7,4	712	309	7,7	71	13	90	96
MIN	6.293	7,0	466	76	7,2	58	3	85	88
MAX	12.662	7,7	964	540	8,7	81	36	92	99
TOTAL	277.913	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Noviembre'14



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	4.202								
2	4.775	7,6	719	380	7,4	54	13	93	96
3	6.242	7,1	615	320	7,3	58	15	91	95
4	6.776	7,7	615	173	7,0	69	4	89	98
5	4.379	7,8	1.084	268	6,8	58	2	95	99
6	4.232	7,6	712	101	6,8	71	4	90	96
7	5.069								
8	5.605								
9	4.282	7,5	831	440	7,5	75	15	91	97
10	4.172	7,6	860	440	7,4	68	15	92	97
11	8.627	7,4	749	148	6,9	80	5	89	97
12	5.241	7,7	756	64	7,6	72	5	90	93
13	6.610	7,6	950	251	7,4	64	9	93	97
14	11.633								
15	5.397								
16	4.740	7,7	548	140	7,4	46	11	92	92
17	4.243	7,7	764	360	7,8	63	15	92	96
18	3.542	7,9	433	92	7,8	50	6	88	94
19	3.687	7,8	563	67	7,6	66	5	88	92
20	3.545	7,7	594	90	7,0	44	2	93	97
21	3.562								
22	3.693								
23	7.796	8,0	588	200	7,5	45	21	92	90
24	4.735	7,5	807	281	6,8	63	21	92	89
25	3.847	7,9	459	66	6,8	59	2	93	99
26	10.102	7,3	543	73	7,1	58	4	87	94
27	13.906	7,3	543	73	7,1	66	3	88	96
28	14.330								
29	11.044								
30	6.361	7,7	659	240	7,2	56	9	92	96
31									
MED	6.213	7,6	685	203	7,2	61	9	91	95
MIN	3.542	7,1	433	64	6,8	44	2	87	89
MAX	14.330	8,0	1.084	440	7,8	80	21	95	99
TOTAL	186.375	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Noviembre'14

