


	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	8.318	7,1	942	441	8,2	95	15	90	97
2	8.164	7,2	838	276	8,0	78	7	91	97
3	8.181	7,1	934	485	7,2	75	6	92	99
4	8.545								
5	7.913								
6	7.158	7,2	912	560	7,3	80	10	91	98
7	7.911	7,1	882	400	7,7	86	22	90	95
8	8.034	7,1	890	410	7,7	90	11	90	97
9	8.235	7,1	808	568	8,2	83	16	90	97
10	8.192	7,1	875	424	7,7	87	11	90	97
11	8.583								
12	8.288								
13	7.636	7,0	838	300	8,2	87	20	90	93
14	8.430	7,2	882	420	7,9	84	19	90	95
15	8.214	7,1	949	234	8,0	83	10	91	96
16	8.160								
17	8.613	7,3	632		9,0	63		90	
18	9.060								
19	7.308								
20	6.866	7,2	606		8,9	48		92	
21	8.005	7,3	930		8,7	70		92	
22	8.046	7,5	938		8,8	62		93	
23	8.157	7,5	804		8,4	56		93	
24	8.233	7,3	847		8,4	68		92	
25	8.544								
26	7.693								
27	6.887	7,2	839		7,7	31		96	
28	7.475	7,6	839		7,7	31		96	
29	7.285	7,4	740		8,0	72		90	
30	7.306	7,2	724		7,3	58		92	
31	7.366	7,5	988		7,2	63		94	
MED	7.961	7,2	847	411	8,0	71	13	92	97
MIN	6.866	7,0	606	234	7,2	31	6	90	93
MAX	9.060	7,6	988	568	9,0	95	22	96	99
TOTAL	246.806	-	-	-	-	-	-	-	-

Rendimientos EDAR El Torno - Junio'12



	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	6.120	7,4	660	302	7,0	82	5	88	98
2	6.984	7,5	459	180	6,9	53	5	88	97
3	7.038	7,4	786	308	7,1	82	6	90	98
4	7.283								
5	7.886								
6	7.789	7,2	712	440	7,4	62	9	91	98
7	7.862	7,3	488	260	7,1	58	18	88	93
8	7.829	7,4	600	372	7,3	65	11	89	97
9	7.910	7,4	704	320	7,5	72	7	90	98
10	7.860	7,3	756	369	7,2	81	8	89	98
11	7.709								
12	8.709								
13	8.829	7,5	816	360	7,1	78	16	90	96
14	8.755	7,6	704	360	7,1	74	23	89	94
15	8.648	7,4	883	114	7,2	79	4	91	97
16	8.606								
17	9.383	7,6	529		7,6	22		96	
18	9.402								
19	9.637								
20	9.688	7,4	990		7,4	30		97	
21	9.037	7,5	527		7,7	66		87	
22	9.066	7,5	689		7,8	45		94	
23	9.574	7,6	600		7,6	38		94	
24	9.207	7,5	567		7,6	48		92	
25	9.210								
26	9.521								
27	9.112	7,2	616		7,5	61		90	
28	8.764	7,5	616		7,6	61		90	
29	8.951	7,6	365		7,7	58		84	
30	8.771	7,6	1.070		7,6	30		97	
31	8.322	7,6	426		7,8	63		85	
MED	8.499	7,5	662	308	7,4	59	10	90	97
MIN	6.120	7,2	365	114	6,9	22	4	84	93
MAX	9.688	7,6	1.070	440	7,8	82	23	97	98
TOTAL	263.462	-	-	-	-	-	-	-	-

Rendimientos EDAR La Barrosa - Junio'12

