



E.D.A.R. La Barrosa

Enero'06

	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	4.376								
2	4.099	7,2	327	200	7,1	28	3	90	97
3	4.106	7,3	482	170	7,2	41	5	92	98
4	4.066								
5	4.102								
6	7.065								
7	4.850								
8	4.525	7,5	373	240	7,5	28	3	92	99
9	4.348	7,8	451	280	7,5	40	9	92	98
10	5.028	8,1	365	240	8,2	31	3	93	99
11	4.156	7,4	249	168	7,4	31	4	87	98
12	4.785	7,4	234	176	7,5	30	4	88	98
13	7.021								
14	4.926								
15	7.371	7,2	257	160	7,1	17	2	94	98
16	5.551	7,2	234	140	7,3	23	7	92	96
17	4.574	7,3	231	106	7,4	19	2	88	98
18	3.303	7,3	256	140	7,3	29	7	90	96
19	3.520	7,4	424	243	7,4	36	6	91	97
20	3.747								
21	4.026								
22	3.729	7,4	214	140	7,5	26	7	90	97
23	3.898	7,5	669	300	7,4	65	3	92	99
24	3.637	7,3	669	250	7,3	44	3	93	99
25	3.041	7,6	382	118	7,5	38	4	91	97
26	6.357	7,6	315	92	7,5	48	3	87	97
27	9.885								
28	8.855								
29	6.417	7,3	669	100	7,0	21	2	97	97
30	9.477	7,4	96	80	7,4	41	3	72	97
31	5.455	7,5	121	56	7,1	38	3	70	96
MED	5.171	7,4	351	170	7,4	34	4	89	97
MIN	3.041	7,2	96	56	7,0	17	2	70	96
MAX	9.885	8,1	669	300	8,2	65	9	97	99
TOTAL	160.296	-	-	-	-	-	-	-	-