

	Caudal entrada	AGUA BRUTA			AGUA TRATADA			REND. ELIMINACION	
		pH	D.Q.O.	D.B.O.5	pH	D.Q.O.	D.B.O.5	D.Q.O.	D.B.O.5
Día	m3/día	-	mg/l	mg/l	-	mg/l	mg/l	%	%
1	6.222	7,1	414	340	7,4	47	5	89	98
2	6.404	7,4	628	340	7,4	33	6	95	98
3	6.183	7,4	560	217	7,4	49	4	91	98
4	6.135	7,5	391	144	7,5	36	4	91	98
5	6.539	7,4	773	172	7,5	59	3	92	99
6	7.139								
7	7.046								
8	6.806	7,6	399	240	7,3	56	9	86	96
9	5.132	7,5	582	340	7,5	36	6	94	98
10	4.835	7,2	506	205	7,4	49	3	90	98
11	5.602								
12	6.173	7,2	445	277	7,2	28	6	94	98
13	6.670								
14	7.147								
15	6.832	7,3	674	320	7,4	53	11	92	97
16	6.426	7,3	529	440	7,7	48	4	91	99
17	10.277	7,4	600	325	7,5	28	5	95	98
18	9.524	7,0	605	305	7,2	30	6	95	98
19	9.281	7,4	338	190	7,4	32	2	91	99
20	9.737								
21	9.219								
22	7.215	7,3	315	180	7,1	37	7	88	96
23	9.553	7,2	208	64	7,0	38	6	82	90
24	7.824	7,2	773	133	7,2	29	1	96	99
25	8.720	7,2	269	196	7,2	32	6	88	97
26	8.899	7,4	269	102	7,2	35	1	87	99
27	7.089								
28	7.565								
29	6.635	7,5	361	180	7,4	47	3	87	98
30	6.509	7,2	483	320	7,4	41	2	91	99
31	5.671								
MED	7.258	7,3	482	240	7,3	40	5	91	98
MIN	4.835	7,0	208	64	7,0	28	1	82	90
MAX	10.277	7,6	773	440	7,7	59	11	96	99
TOTAL	225.009	-	-	-	-	-	-	-	-